



**ADDENDUM # 1**  
**BID # PW090001**  
**PROJECT: Carpet Replacement**

April 28, 2009

To: All Bidders

Bid Response Due: May 19, 2009 @ 2:00 pm

For: California State University, Sacramento  
6000 J Street  
Sacramento, Ca 95819-6008

The above referenced bid is hereby amended as follows:

Change in Contract Specifications Section 09680 item 2.04(A) 1 Styles: Style C Wayfarer has been discontinued. Below is the acceptable substitute:

**Style C Applause II RS Vinyl Cushion (Color: TBD)**


A. Construction:	Level Loop
B. Gauge:	1/13
C. Stitch Rate:	8.2 / inch
D. Tuft Density:	104.96 tufts/sq inch
E. Pile Height Average:	0.117 inch
F. Pile Thickness:	0.087 inch
G. Density Factor	UM44D):7448 oz/cu yd
H. Fiber System:	TDX Nylon
I. Dye Method:	50% Solution Dyed/50% Yarn Dyed

**Backing System**

J. Product Width	6 ft.
K. Primary Tufting Substrate	Synthetic Non-Woven
L. Fusion Coat	Sealant Vinyl
M. Backing	Closed-Cell Vinyl Cushion
N. Weight	35.5 oz/sq yd
O. Density	18.5 lbs/cu ft
P. Thickness	0.156 inch
Q. Compression Set	Max 10%
R. Compression Deflection	Min 7 lbs/sq inch @ 25% Max 25 lbs/sq inch @ 25%
S. RS Adhesive System	Applied to 100% of backing
at time of manufacturing	

THIS ADDENDUM IS APPLICABLE TO THE BID DESIGNATED HEREIN. BIDDER SHALL ACKNOWLEDGE ACCEPTANCE OF THIS ADDENDUM ON THE BID PROPOSAL FORM. ALL CONDITIONS NOT AFFECTED BY THIS ADDENDUM SHALL REMAIN THE SAME AS INDICATED IN THE ORIGINAL BID PACKAGE.

Thank you.

A handwritten signature in black ink, appearing to read 'Suzanne Swartz', written in a cursive style.

Suzanne Swartz  
Contract Administrator  
(916) 278-5797  
[swartzsd@csus.edu](mailto:swartzsd@csus.edu)