

The following checklist is a guide. It may be used in its entirety or be modified to the specific user's needs by adding or subtracting items from the checklist. For questions concerning any item, contact the Office of Environmental Health and Safety.

(9) ELEVATED SURFACES

Name: _____ Date : _____

Location of Inspection: _____

1. Are signs posted, when appropriate, showing the elevated surface load capacity?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____
2. Are surfaces elevated more than 30 inches above the floor or ground provided with standard guardrails?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____
3. Are all elevated surfaces (beneath which people or machinery could be exposed to falling objects) provided with standard 4-inch toeboards?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____
4. Is a permanent means of access and egress provided to elevated storage and work surfaces?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____
5. Is required headroom provided where necessary?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____
6. Is material on elevated surfaces piled, stacked or racked in a manner to prevent it from tipping, falling, collapsing, rolling or spreading?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____
7. Are dock boards or bridge plates used when transferring materials between docks and trucks or rail cars?	Yes <input type="checkbox"/> No <input type="checkbox"/>	Comments: _____ _____