

The following checklist is a guide. It may be used in its entirety or be modified to the specific user's needs by adding or subtracting items from the checklist. For questions concerning any item, contact the Office of Environmental Health and Safety.

(26) IDENTIFICATION OF PIPING SYSTEMS

Name: _____ Date : _____

Location of Inspection: _____

<p>1. When non-potable water is piped through a facility, are outlets or taps posted to alert employees that it is unsafe and not to be used for drinking, washing or other personal use?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____ _____</p>
<p>2. When hazardous substances are transported through above ground piping, is each pipeline identified at points where confusion could introduce hazards to employees?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____ _____</p>
<p>3. When color painting identifies pipelines, are all visible parts of the line so identified?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>
<p>4. When pipelines are identified by color painted bands or tapes, are the bands or tapes located at reasonable intervals and at each outlet, valve or connection?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>
<p>5. When pipelines are identified by color, is the color code posted at all locations where confusion could introduce hazards to employees?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>
<p>6. When the contents of pipelines are identified by name or name abbreviation, is the information readily visible on the pipe near each valve or outlet?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>

<p>7. When pipelines carrying hazardous substances are identified by tags, are the tags constructed of durable materials, the message carried clearly and permanently distinguishable and are tags installed at each valve or outlet?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____ _____</p>
<p>8. When electricity, steam or other external source heats pipelines, are suitable warning signs or tags placed at unions, valves, or other serviceable parts of the system?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____ _____</p>
<p>9. Are open lights, open flames, or sparking or arcing equipment prohibited near fueling or transfer of fuel operations?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>
<p>10. Is smoking prohibited in the vicinity of fueling operations?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>
<p>11. Are fueling operations prohibited in building or other enclosed areas that are not specifically ventilated for this purpose?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____ _____</p>
<p>12. Where fueling or transfer of fuel is done through a gravity flow system, are the nozzles of the self-closing type?</p>	<p>Yes <input type="checkbox"/> No <input type="checkbox"/></p>	<p>Comments: _____ _____</p>