INSPECTION CHECKLISTS

CALIFORNIA STATE UNIVERSITY SACRAMENTO

The following checklist is a guide. It may be used in its entirety or be modified to the specific user's needs by adding or subtracting items from the checklist. For questions concerning any item, contact the Office of Environmental Health and Safety.

(37) POWDER ACTUATED TOOLS

Name:	Date :	
Location of Inspection:		
1. Are employees who operate powder-actuated tools trained in their use and carry a valid operator's card?	Yes 🗆 No 🗆	Comments:
2. Do the powder-actuated tools being used have written approval of the Division of Occupational Safety and Health?	Yes 🗆 No 🗆	Comments:
3. Is each powder-actuated tool stored in its own locked container when not being used?	Yes 🗌 No 🗌	Comments:
4. Is a sign at least 7" by 10" with bold type reading "POWDER- ACTUATED TOOL IN USE" conspicuously posted when the tool is being used?	Yes 🗆 No 🗆	Comments:
5. Are powder-actuated tools left unloaded until they are actually ready to be used?	Yes 🗆 No 🗆	Comments:
6. Are powder-actuated tools inspected for obstructions or defects each day before use?	Yes 🗆 No 🗆	Comments:
7. Do powder-actuated tools operators have and use appropriate personal protective equipment such as hard hats, safety goggles, safety shoes and ear protectors?	Yes 🗆 No 🗆	Comments: